



ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr.
75964-0000, TX Nacogdoches
Phone: 936-569-7941
Fax: 936-560-4685



2058 Rac 2" Emt CNDT HNGR *Hubbell--Raco*

| | |
|------------------|---|
| Catalog Number | 2058 |
| Manufacturer | Hubbell--Raco |
| Description | Conduit Hangers With Nut and Bolt, Steel, 5 Trade Size, 2 In. Rigid&Imc Size, 2 In. Emt Size |
| Weight per unit | 0.2520 (lbs/each) |
| Product Category | Rigid Conduit Fittings - Steel |

Features

| | |
|-----------------|-------|
| Material | Steel |
| pallet quantity | 2400 |

Material, Color, and Finish

| | |
|-------|--------|
| Color | Silver |
|-------|--------|

Dimensions and Weight

| | |
|------|-------------------------------|
| Size | 3.875 in x 1.25 in x 2.344 in |
|------|-------------------------------|

Descriptions

| | |
|------------------------|---|
| Construction | One piece hanger with nut and bolt |
| Description | RAC 2" EMT CNDT HNGR |
| extra long description | RACO 2058 CONDUIT HANGER 2 IN RGD/E |
| Long Description | Conduit Hangers with Nut and Bolt, Steel, 5 Trade Size, 2 In. Rigid&IMC Size, 2 In. EMT Size |
| Product Type | Conduit Hanger 2 In RGD/Emt (TS 5) |
| Special Features | wet or dry locations, pregalvanized finish provides corrosion protection |

Manufacturer Information

| | |
|---------------------------|----------------|
| Brand | RACO |
| GTIN | 00050169020586 |
| Manufacturers Part Number | 2058 |
| UPC | 050169020586 |

Taxonomies, Classifications, and Categories

| | |
|----------------------|---------------------------|
| Category Description | CABLE & PIPE TRANSITS |
| Type | Rigid/IMC and EMT conduit |

Packaging

| | |
|-----------------|-------|
| Carton | 1 |
| Weight Per each | 0.252 |



ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr.
75964-0000, TX Nacogdoches
Phone: 936-569-7941
Fax: 936-560-4685

Uses, Certifications, and Standards

Application

For use in wet or dry locations to support runs of rigid/IMC and EMT conduit from ceilings and walls

standard

UL 514B