



ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr.
75964-0000, TX Nacogdoches
Phone: 936-569-7941
Fax: 936-560-4685



CS85 2/0 to 2/0 Alcu Splice

Abb Installation Products, Inc

| | |
|------------------|--|
| Catalog Number | CS85 |
| Manufacturer | Abb Installation Products, Inc |
| Description | Service Entrance Compression Splice, 2/0 Awg (Stranded) Conductor Size, Non-Insulated, Copper/Aluminum Conductor Material, 2 In Overall Length, Compression/Crimp Terminal, 0.04 LB/Ea |
| Weight per unit | 0.0430 (lbs/each) |
| Product Category | Large Terminals & Connectors |

Features

| | |
|----------------------|-------------|
| connection | Compression |
| insulation | None |
| Material | Aluminum |
| Number of Conductors | 2 |

Dimensions and Weight

| | |
|------|--------|
| Size | 2 INCH |
|------|--------|

Descriptions

| | |
|------------------------|-------------------------------------|
| Description | 2/0 TO 2/0 ALCU SPLICE |
| extra long description | ABB CS85 AL SERVENTR COMP SPLICE A: |

Manufacturer Information

| | |
|-------|----------------------|
| Brand | Blackburn Mechanical |
| GTIN | 00783786101108 |
| UPC | 783786101108 |

Taxonomies, Classifications, and Categories

| | |
|----------------------|-------------------------------------|
| Category Description | Comp & Mech Lugs and Butt Splices |
| Type | Compression Splice Service Entrance |

Packaging

| | |
|-----------------|-------|
| Carton | 100 |
| Package | 800 |
| Weight Per each | 0.043 |



ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr.
75964-0000, TX Nacogdoches
Phone: 936-569-7941
Fax: 936-560-4685

Uses, Certifications, and Standards

| | |
|--------------------------|---|
| Application | Basic, uninsulated Splices for Service Entrances. For Combinations of Aluminum-to-Aluminum or Aluminum-to-Copper Conductors |
| environmental conditions | All Seasons / Conditions |
| Mounting standard | None |
| | RUS Accepted. Complies with ANSI C119.4 when properly installed on Aluminum-to-Aluminum or Aluminum-to-Copper Conductors |