

## ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr. 75964-0000, TX Nacogdoches Phone: 936-569-7941 Fax: 936-560-4685



## **E945E 3/4" SCH40 Expn CPLG** Abb Installation Products, Inc

Uses, Certifications, and Standards

standard

**Application** 

| Catalog Number                     | E945E  |
|------------------------------------|--|
| Manufacturer                       | Abb Installation Products, Inc   |
| Description                        | Coupling End Expansion Fitting, Size 3/4 Inch, Material PVC, Color Gray, For Use With Schedule 40 and 80, Pack Of 15 |
| Weight per unit                    | 0.2700 (lbs/each)  |
| Product Category                   | DVC Clamps Strong Eve CDICS  |
| Material, Color, and Finish        |  |
| Color                              | Gray   |
| Descriptions                       |  |
| Description                        | 3/4" SCH40 EXPN CPLG   |
| extra long description             | ABB E945E 3/4 IN SCH 40 EXPANSION C  |
| Long Description                   | Coupling End Expansion Fitting, Size 3/4 Inch, Material PVC, Color Gray, For use with Schedule 40 and 80, Pack of 15 |
| Product Type                       | 3/4 In SCH 40 Expansion Coupling   |
| Special Features                   | Exclusive molded in mid-point indicator on the piston  |
| Manufacturer Information           |  |
| Brand                              | Carlon   |
| GTIN                               | 00034481061229   |
| Manufacturers Part Number          | E945E  |
| UPC                                | 034481061229   |
| Taxonomies, Classifications, and C | Categories   |
| Category Description               | COUPLINGS, ADAPTERS, REDUCERS, BUSHINGS, & CAPS  |
| Туре                               | Expansion Fittings   |
| Packaging                          |  |
| Carton                             | 15   |
| Weight Per each                    | 0.27   |
|                                    |  |

UL E23018

Designed to compensate for length changes due to temperature

variations in exposed conduit runs