



ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr.
75964-0000, TX Nacogdoches
Phone: 936-569-7941
Fax: 936-560-4685



RC3 3" Beam Clamp

Abb Installation Products, Inc

| | |
|------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Catalog Number | RC3 |
| Manufacturer | Abb Installation Products, Inc |
| Description | Clamp, RC Beam, Outer Diameter Of Conduit or Pipe 3.500 Inches, Nominal Conduit Size 3 Inches, Malleable Iron, For Mounting Pipe or Conduit Parallel to The Beam |
| Weight per unit | 1.2 (lbs/each) |
| Product Category | Channel & Strut Fittings |

Features

| | |
|----------|----------------|
| Material | Malleable Iron |
|----------|----------------|

Material, Color, and Finish

| | |
|--------|------------|
| Finish | Galvanized |
|--------|------------|

Dimensions and Weight

| | |
|------|---|
| Size | 3 |
|------|---|

Descriptions

| | |
|------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Description | 3" BEAM CLAMP |
| extra long description | ABB RC 3 RC BEAM CLP COND SZ 3IN MA |
| Long Description | Clamp, RC Beam, Outer Diameter of Conduit or Pipe 3.500 Inches, Nominal Conduit Size 3 Inches, Malleable Iron, For Mounting Pipe or Conduit Parallel to the Beam |
| Product Type | RC Beam CLP Cond SZ 3IN Mall Iron |

Manufacturer Information

| | |
|---------------------------|----------------|
| Brand | Steel City |
| GTIN | 00785991503265 |
| Manufacturers Part Number | RC 3 |
| UPC | 785991503265 |

Taxonomies, Classifications, and Categories

| | |
|----------------------|-----------------------------------|
| Category Description | BEAM, RA, EDGE, & PARALLEL CLAMPS |
| Type | Beam Clamps |

Packaging

| | |
|-----------------|------|
| Carton | 25 |
| Weight Per each | 1.16 |

Uses, Certifications, and Standards

| | |
|-------------|------------------------------|
| Application | For use with conduit or pipe |
|-------------|------------------------------|