



**MILBANK**<sup>®</sup>  
ENERGY AT WORK

## U3862



Catalog Number	U3862
Marketing Product Description	60 Ampere Fused Alternating Current Disconnect Pull Out
UPC	784572586932
Length (IN)	3.107
Width (IN)	5.2
Height (IN)	9.25
Weight (LB)	4
Brand Name	Milbank
Type	Air Conditioner Disconnect
Special Features	10 Horse Power
Application	Metering Accessory
Standard	UL Listed;Type 3R
Voltage Rating	Up to 240 Volts Alternating Current
Amperage Rating	60 Ampere
Interrupt Rating	10,000 Ampere Interrupting Capacity
Number Of Poles	2
Trip Type	Thermal Overload and Short Circuit Current
Contact Configuration	Pull Out
Contact Rating	60 Ampere Up to 240 Volts Alternating Current
Connection	Pullout

Enclosure	Painted Steel
Mounting	Surface Mount
Size	3.107L x 5.2W x 9.25H
Conduit Connection	Knockouts

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.



**MILBANK**<sup>®</sup>  
ENERGY AT WORK

## U3862



Catalog Number	U3862	Enclosure	Painted Steel
Marketing Product Description	60 Ampere Fused Alternating Current Disconnect Pull Out	Mounting	Surface Mount
UPC	784572586932	Size	3.107L x 5.2W x 9.25H
Length (IN)	3.107	Conduit Connection	Knockouts
Width (IN)	5.2		
Height (IN)	9.25		
Weight (LB)	4		
Brand Name	Milbank		
Type	Air Conditioner Disconnect		
Special Features	10 Horse Power		
Application	Metering Accessory		
Standard	UL Listed;Type 3R		
Voltage Rating	Up to 240 Volts Alternating Current		
Amperage Rating	60 Ampere		
Interrupt Rating	10,000 Ampere Interrupting Capacity		
Number Of Poles	2		
Trip Type	Thermal Overload and Short Circuit Current		
Contact Configuration	Pull Out		
Contact Rating	60 Ampere Up to 240 Volts Alternating Current		
Connection	Pullout		

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.