

XTCEXF_



Frames D–G—Two-Pole

Conventional Thermal Current,
Open at 60°C
 $I_{th} = I_e$, AC-1 in Amps

| | Contact Configuration | Circuit Symbol | Pkg. Qty. ① | Screw Terminal Catalog Number |
|----|-----------------------|----------------|-------------|-------------------------------|
| 16 | 2NO | | 5 | XTCEXFBG20 |
| 16 | 1NO-1NC | | 5 | XTCEXFAG11 |
| 16 | 1NO-1NC | | 5 | XTCEXFBG11 |
| 16 | 2NC | | 5 | XTCEXFBG02 |

XTCEXF_



Frames D–G—Four-Pole

Conventional Thermal Current,
Open at 60°C
 $I_{th} = I_e$, AC-1 in Amps

| | Contact Configuration | Circuit Symbol | Pkg. Qty. ① | Screw Terminal Catalog Number |
|----|------------------------------------|----------------|-------------|-------------------------------|
| 16 | 4NO-0NC | | 5 | XTCEXFBG40 |
| 16 | 3NO-1NC | | 5 | XTCEXFBG31 |
| 16 | 2NO-2NC | | 5 | XTCEXFBG22 |
| 16 | 2NO-2NC | | 5 | XTCEXFAG_22 ② |
| 16 | 1NO-3NC | | 5 | XTCEXFBG13 |
| 16 | 0NO-4NC | | 5 | XTCEXFBG04 |
| 16 | 1NO _E -1NC _L | | 5 | XTCEXFBG22 ③ |

Notes

Interlocked opposing contacts, to IEC/EN 60947-5-1 Annex L (positively driven), within the auxiliary contact modules (not NO (early make) and NC (late break) contacts) and for the built-in auxiliary contacts of the XTCE007B_–XTCE032C_.

Auxiliary break contact can be used as mirror contact to IEC/EN 60947-4-1 Annex F (not NC (late break) contact).

No auxiliary contacts can be fitted between two contactors.

① Orders must be placed in multiples of package quantity listed.

② A “_” denotes catalog numbers are incomplete. To complete the catalog number for ordering a spring cage terminal, insert a **C** in the “_” position or remove “_” for screw type terminal.

③ One early-make contact (1NO_E), one late-break contact (1NC_L).

XTCEXF_



Frames D–G—Two-Pole

Conventional Thermal Current,
Open at 60°C
 $I_{th} = I_e$, AC-1 in Amps

| | Contact Configuration | Circuit Symbol | Pkg. Qty. ① | Screw Terminal Catalog Number |
|----|-----------------------|----------------|-------------|-------------------------------|
| 16 | 2NO | | 5 | XTCEXFBG20 |
| 16 | 1NO-1NC | | 5 | XTCEXFAG11 |
| 16 | 1NO-1NC | | 5 | XTCEXFBG11 |
| 16 | 2NC | | 5 | XTCEXFBG02 |

XTCEXF_



Frames D–G—Four-Pole

Conventional Thermal Current,
Open at 60°C
 $I_{th} = I_e$, AC-1 in Amps

| | Contact Configuration | Circuit Symbol | Pkg. Qty. ① | Screw Terminal Catalog Number |
|----|------------------------------------|----------------|-------------|-------------------------------|
| 16 | 4NO-0NC | | 5 | XTCEXFBG40 |
| 16 | 3NO-1NC | | 5 | XTCEXFBG31 |
| 16 | 2NO-2NC | | 5 | XTCEXFBG22 |
| 16 | 2NO-2NC | | 5 | XTCEXFAG_22 ② |
| 16 | 1NO-3NC | | 5 | XTCEXFBG13 |
| 16 | 0NO-4NC | | 5 | XTCEXFBG04 |
| 16 | 1NO _E -1NC _L | | 5 | XTCEXFBG22 ③ |

Notes

Interlocked opposing contacts, to IEC/EN 60947-5-1 Annex L (positively driven), within the auxiliary contact modules (not NO (early make) and NC (late break) contacts) and for the built-in auxiliary contacts of the XTCE007B_–XTCE032C_.

Auxiliary break contact can be used as mirror contact to IEC/EN 60947-4-1 Annex F (not NC (late break) contact).

No auxiliary contacts can be fitted between two contactors.

① Orders must be placed in multiples of package quantity listed.

② A “_” denotes catalog numbers are incomplete. To complete the catalog number for ordering a spring cage terminal, insert a **C** in the “_” position or remove “_” for screw type terminal.

③ One early-make contact (1NO_E), one late-break contact (1NC_L).